

MOUNTING INSTRUCTIONS FOR KEA 16-40A
 ASENNUSOHJE KUA 16-25A
 MONTERINGSANVISNING FÖR KUA 16-25A

<p>①</p> <p>88</p> <p>106</p>	<p>③ Option 1: knock outs</p> <p>PZ2/1x5 1,8 Nm MAX 16 mm² Cu</p> <p>4 x Ø25</p> <p>Option 2: Threading 2xM25+M16 or 4xM25+M16</p> <p>NOTE: IP code (IEC 60529) IP66, When used IP66 or better cable entries.</p>
<p>②</p> <p>Ø9,0 MAX</p> <p>Ø4,5 MAX</p>	<p>④</p> <p>OFF O</p> <p>⑤</p> <p>PZ2/1x5 2-2.2 Nm</p> <p>Defeat mechanism Ohitusmekanismi Förbi koppling</p> <p>ON I</p>