

Dokument			Anvisning nr
<b>CERTIFICATE OF CONFORMITY</b>			<b>8.2-14</b>
Utarbetad av	Godkänd av	Datum/utgåva nr	Sida
Roland Sköld	Patrick Flystam	040202/1	1(1)

# CERTIFICATE OF CONFORMITY

We hereby certify that these product has been produced and approved according to following:

MANUFACTURER	AMO Kraftkabel AB Kabelvägen 5 360 75 Alstermo Sweden
CUSTOMER	Elektrilevi, Estonia
ORDER NO.	Tender
PRODUCT	Covered overhead conductor, CCST
TYPE DESIGNATION	CCST 62 ACSR 20(24)kV W CCST 99 ACSR 20(24)kV W
STANDARD	EN 50397-1, conductors according to EN50182
COMMENT	Both conductors, 51-AL1/9-ST1A (Raven) and 85-AL1/14-ST1A (Pigeon) are manufactured according to EN50182:2005 Table F38. Third party type test according to EN50397-1 has been performed by SP- Laborities, Sweden in report 5F 017738 A. The test results applies to CCST ACSR covered overhead conductor also and conductor material does not change the performance characteristics of covered overhead line with ACSR conductor compared to AL7 covered conductor by mean of EN 50397:1-2006 clause 3.1.1.

PARAMETER	MEASURED VALUE	REQUIREMENT	TEST METHOD
Not.			

Quality control department, 2017-04-13  
AMO Kraft AB

Fredrik Warme  
Plant Manager